

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Our water system recently violated drinking water standards. Although this was not an emergency, as our customers, you have a right to know what happened, what you should do, and what we are doing to correct this situation.

Altus AFB Has Levels of Total Trihalomethanes (TTHMs) Above Drinking Water Standards

We routinely monitor for the presence of drinking water contaminants. Testing results we received for the indicated time period(s) show that our system exceeds the standard, or maximum contaminant level (MCL), for total trihalomethanes (TTHM). The standard or MCL for TTHM is 0.080 mg/L. It is determined by averaging all the samples collected at each sampling location for the past 12 months. The level of total trihalomethanes averaged at our system's locations was the following:

<u>Twelve-month time period</u>	<u>Locational Running Annual Average with Sample Location</u>
Second Quarter 2025	0.104 MG/L - BUILDING #1
Second Quarter 2025	0.092 MG/L - BUILDING #492
First Quarter 2025	0.119 MG/L - BUILDING #492
First Quarter 2025	0.134 MG/L - BUILDING #1

What should I do? There is nothing you need to do unless you have a severely compromised immune system, have an infant or are elderly. These people may be at increased risk and should seek advice about drinking water from their health care providers.

What does this mean? This is not an emergency. If it had been, you would have been notified immediately.

However, some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous system, and may have an increased risk of getting cancer.

CORRECTIVE ACTION: What happened? What is being done? When will the violation be resolved?

Altus Air Force Base conducted compliance sampling for Total Trihalomethanes (TTHMs) during the 1st and 2nd quarters of 2025 and went into violation of the Disinfection Byproduct Rule (DBPR) starting in the 3rd quarter of 2025. The base is actively collaborating with the City of Altus to address this issue and develop a comprehensive mitigation plan. Additionally, the base is working to establish a new water entry point.

For further information contact: 1st Lt Hassan Ouro-Gneni

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice is being sent to you by Altus AFB

PWS Number OK3003303 Date distributed: _____